

c-37

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**


No. F6/DFS/MS/School/WZ/2020/416

Dated: 12/10/2020

**FIRE SAFETY CERTIFICATE**

Certified that the Kendriya Vidyalaya, Sec-22, Running at Sector-3, Rohini, Delhi-110085, comprised of Ground floor only owned/occupied by Kendriya Vidyalaya was issued fire safety certificate by this department vide letter no F.6/DFS/MS/2017/School/WZ/334 dated 08.03.2017. The premises was re-inspected by the officer concerned of this department on 19.09.2020 in the presence of Mr. Anil Kumar (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "B" Educational Buildings with effect from 12/10/2020 for a period of three years subject to compliance of the conditions mentioned below.

Issued on 12/10/2020 at New Delhi by

  
**(Dhrrampal Bhardwaj)**  
**Dy.Chief Fire Officer**  
**Tel:-01123414250**

**Copy to:**

1. The Principal, Kendriya Vidyalaya, Sec-22, Running at Sector-3, Rohini, Delhi-110085
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

**Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on [http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms/](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms/)

1. Name & address of the building : Kendriya vidyalaya Sec-22, Kunning at Sector-5, Konini  
Delhi-110085
2. Type of Occupancy : Educational
3. Type of Case : Renewal ( Ground Floor only )
4. Details of previous NOC : F.6/DFS/MS/2017/School/WZ/334 dated 08.03.2017
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 19.09.2020
7. Name of the Inspecting Officers : ADO (Rohini)
8. Name and designation of officers  
from the building side : Mr. Anil Kumar (Principal)
9. Year of Construction : 2006
10. Applicant's letter No. : F.4-4/KVRS-22/2020-2021/1130 Dated 14.08.2020

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6.0m	09 mtr	M/R
	• Gate width	4.5m	3.5m	M/R (Old case)
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mtr	1.0 mtr	M/R
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			






	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found some shortcomings.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DPS/MS/2017/School/WZ/334 dated 08.03.2017 Renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

  
Signature of the Inspecting Officer  
Name :- Ajay Sharma  
Designation:- ADO/Rohini

