

286

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2024/School/WZ/ 51

Dated: 23/01/2024

FIRE SAFETY CERTIFICATE

Certified that the **Kendriya Vidyalaya, Sec-22, Running at Pocket-16-D, Sector-3, Rohini, Delhi-11008**, comprised of **Ground floor only** owned/occupied by **Kendriya Vidyalaya** was granted FSC by this department vide letter No. **F.6/DFS/MS/School/WZ/2020/416** dated **12.10.2020**. The premises was re-inspected by the officer concerned of this department on **15.01.2024** in the presence of **Mr. Anil kumar (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 23/01/2024 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 23/01/2024 at New Delhi


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Kendriya Vidyalaya, Sec-22, Running at Pocket-16-D, Sector-3, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

Name & address of the building		Kendriya Vidyalaya, Sec-22, Running at Pocket-16-D, Sector-3, Rohini, Delhi-110085.		
2. Type of Occupancy		Educational		
3. Type of Case		Renewal (04 Blocks, Ground floors only)		
4. Details of Previous NOC		F.6/DFS/MS/School/WZ/2020/416 dated 12.10.2020.		
5. Fire Safety directives letter No		Director of Education Cir. dated 01.03.2011.		
6. Date of inspection		15.01.2024.		
7. Name of Inspecting Officer		Sh. Ajay Kumar Sharma (ADO Rohini)		
8. Name and designation of officers From the building side		Mr. Anil Kumar (Principal)		
9. Year of Construction		2006		
10. Applicant's letter No.		Online e-mail dated 11.01.2024.		
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	• Road width	Accessible	Accessible	MR(Old case)
	• Gate width	Accessible	3.5m	
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	a) Total numbers	06nos.	10nos.	MR
	b) Types	ABC/CO2	ABC-10nos.	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	-NA-	-NA-	-NA-
	b) Length of hose reel hose	-NA-	-NA-	-NA-
	c) Nozzle diameter	-NA-	-NA-	-NA-

7. Automatic fire detection and alarming system			
a) Type of detectors	-NA-	-NA-	-NA-
b) Location of Main Panel	-NA-	-NA-	-NA-
c) Location of Repeater Panel	-NA-	-NA-	-NA-
d) Alternate source of power	-NA-	-NA-	-NA-
e) Hooters' Location	-NA-	-NA-	-NA-
8. MOEFA	-NA-	-NA-	-NA-
9. Public Address System	-NA-	-NA-	-NA-
10. Automatic Sprinkler System			
a) Basement	-NA-	-NA-	-NA-
b) Ground & Upper Floors	-NA-	-NA-	-NA-
c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11. Internal Hydrants			
a) Size of riser/down-comer	-NA-	-NA-	-NA-
b) Number of hydrants per floor	-NA-	-NA-	-NA-
c) Hose Box	-NA-	-NA-	-NA-
12. Yard Hydrants			
a) Total number of hydrants	-NA-	-NA-	-NA-
b) Hose Box	-NA-	-NA-	-NA-
13. Pumping Arrangements			
• Ground Level	-NA-	-NA-	-NA-
➤ Discharge of main Pump	-NA-	-NA-	-NA-
➤ Head of Main pump	-NA-	-NA-	-NA-
➤ Number of main pumps	-NA-	-NA-	-NA-
➤ Jockey Pump out put	-NA-	-NA-	-NA-
➤ Jockey pump head	-NA-	-NA-	-NA-
➤ Standby Pump out put	-NA-	-NA-	-NA-
➤ Standby Pump Head	-NA-	-NA-	-NA-
➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
➤ Pump House Access	-NA-	-NA-	-NA-
Terrace level			
➤ Discharge of pump	-NA-	-NA-	-NA-
➤ Head of the pump	-NA-	-NA-	-NA-
➤ Power Supply	-NA-	-NA-	-NA-
➤ Auto Starting of pump	-NA-	-NA-	-NA-
14. Captive Water Storage for fire fighting			
• Underground tank capacity	-NA-	-NA-	-NA-
➤ Draw-off connection	-NA-	-NA-	-NA-
➤ Fire service inlet	-NA-	-NA-	-NA-
➤ Access to tank	-NA-	-NA-	-NA-
• Overhead Tank capacity	-NA-	-NA-	-NA-
15. Exit Signage.	-NA-	-NA-	-NA-
16. Provision of Lifts.			
a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
c) Communication In lift Car	-NA-	-NA-	-NA-
d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
e) Lift Signage	-NA-	-NA-	-NA-
17. Standby power supply	-NA-	-NA-	-NA-

[Handwritten marks]

Refuge Area.			
a) Total Area	-NA-	-NA-	-NA-
b) Location	-NA-	-NA-	-NA-
Fire Control Room			
a) Detector System Panel	-NA-	-NA-	-NA-
b) Flow Switch Panel	-NA-	-NA-	-NA-
c) PA System Panel	-NA-	-NA-	-NA-
d) Battery backup	-NA-	-NA-	-NA-
e) Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2020/416 dated 12.10.2020 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
16/11/24

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Dy. CFO(WZ) *[Signature]*
12/11

5.30
Date 17/11/24

[Signature]
17/11/2024
Director
[Signature]
17/11/24
Ayaj Sharma

Fi letter is put up for kind
perusal and signature please.

[Signature]
19/11/24
Director

[Signature]
19/11/24

Dept Login Search			
Order			
Click on Order Number for complete detail			
Order Number	Order Date	Department	Order Subject
Comp.No: Odr(2024)/25/27258	23/1/2024	Delhi Fire Services	GOVT SARVODAYA BAL VIDYALAYA R BLOCK MANGOL PURI SCHOOL ID 1412011
Comp.No: Odr(2024)/25/27276	23/1/2024	Delhi Fire Services	NIGAM PRATIBHA BAL VIDHYALAYA MANGOLPUR KALAN
Comp.No: Odr(2024)/25/27274	23/1/2024	Delhi Fire Services	KENDRIYA VIDYALAYA SEC 22 POCKET 16 D SECTOR 3 ROHINI
Comp.No: Odr(2024)/25/27275	23/1/2024	Delhi Fire Services	MALIK BANQUET HALL PROP NO 242 FASIL ROAD BAZAR DELHI GATE
Comp.No: Odr(2024)/25/27244	19/1/2024	Delhi Fire Services	RAJKIYA PRATIBHA VIKAS VIDHALAYA SECTOR 05 DWARKA
Comp.No: Odr(2024)/25/27250	19/1/2024	Delhi Fire Services	SARVODAYA BAL VIDYALAYA TUGHLAKABAD EXTENSION SCHOOL ID 1925056
Comp.No: Odr(2024)/25/27232	19/1/2024	Delhi Fire Services	DELHI TEACHERS TRAINING COLLEGE 340 DEENPUR BUS STOP NAJAFGARH
Comp.No: Odr(2024)/25/27236	19/1/2024	Delhi Fire Services	MANUSHREE BUILDING PLOT NO A 42 43 44 COMMERCIAL COMPLEX DR MUKHARJEE NAGAR
Comp.No: Odr(2024)/25/27237	19/1/2024	Delhi Fire Services	MCD PRIMARY SCHOOL SAVITRI NAGAR (GIRLS)
Comp.No: Odr(2024)/25/27247	19/1/2024	Delhi Fire Services	SANT HARI DASS COLLEGE OF HIGHER EDUCATION OPP AIR FORCE STATION BANI